



**CENTER FOR TESTING AND EUROPEAN CERTIFICATION LTD**  
Notified body NB 1871  
23 Sv. Patriarh Evtimij Blvd., Stara Zagora Bulgaria,  
tel. 00 35942/620 368; fax:00359 42/602 377; GSM: 00 359 887 598 697  
E-mail: [ctec@ctec-sz.com](mailto:ctec@ctec-sz.com), [www.ctec-sz.com](http://www.ctec-sz.com)

CONSTRUCTION PRODUCTS TESTING LABORATORY

page 1 total pages 5

**REPORT**  
**FROM INITIAL TYPE TESTING**

**№ 1 18 4602 / 11.12.2013**

The testing is performed in accordance with the requirements of Annex V of Regulation (EU) No 305/2011 laying down harmonized conditions for the marketing of construction products, under system 3 for conformity assessment

**1. Adhesives for tiles:**

*Adhesive for ceramic tiles EXTRA FLEX granite and marble adhesion mortar- white made from Fixkim Pazarlama A.Ş.*

**2. Test requested by:**

*Fixkim Pazarlama A.Ş., Istanbul Deri Organize Sanayi Bölgesi 3.Yol H-21 Tuzla/Istanbul-TURKEY application № 2-0900/11.10.2013*

**3. Test methods:**

*BDS EN 1346:2008 Adhesives for tiles - Determination of open time*

*BDS EN 1348:2008 Adhesives for tiles - Determination of tensile adhesion strength for cementitious adhesives*

*BDS EN 1308:2009 Adhesives for tiles - Determination of slip*

*BDS EN 12002:2009 Adhesives for tiles - Determination of transverse deformation for cementitious adhesives and grouts*

**4. Date of delivery and quantity of samples for testing:** 11.10.2013, 1 sample – 25 kg

**5. Date of test:** 11.10.2013 -09.12.2013

**6. Result:**

The sample submitted for testing by adhesive for tiles EXTRA FLEX granite and marble adhesion mortar- white is classified as a type **C2TES2** adhesive according to the EN 12004:2007+A1:2012

Laboratory manager .....

/ eng. H. Angelova /

