



CENTER FOR TESTING AND EUROPEAN CERTIFICATION LTD
Notified body NB 1871
23 Sv. Patriarh Evtimij Blvd., Stara Zagora Bulgaria,
tel. 00 35942/620 368; fax:00359 42/602 377; GSM: 00 359 887 598 697
E-mail: ctec@ctec-sz.com, www.ctec-sz.com

CONSTRUCTION PRODUCTS TESTING LABORATORY

page 1 total pages 5

REPORT
FROM INITIAL TYPE TESTING

№ 1 18 4605 / 27.12.2013

The testing is performed in accordance with the requirements of Annex V of Regulation (EU) No 305/2011 laying down harmonized conditions for the marketing of construction products, under system 3 for conformity assessment

1. Adhesives for tiles:

Adhesive for ceramic tiles Ceramic adhesion mortar- grey made from Fixkim Pazarlama A.Ş.

2. Test requested by:

*Fixkim Pazarlama A.Ş., Istanbul Deri Organize Sanayi Bölgesi 3.Yol H-21 Tuzla/Istanbul-TURKEY
application № 2-0901/11.10.2013*

3. Test methods:

BDS EN 1346:2008 Adhesives for tiles - Determination of open time

BDS EN 1348:2008 Adhesives for tiles - Determination of tensile adhesion strength for cementitious adhesives

BDS EN 1308:2009 Adhesives for tiles - Determination of slip

4. Date of delivery and quantity of samples for testing: *11.10.2013, 1 sample – 25 kg*

5. Date of test: *07.11.2013 -20.12.2013*

6. Result:

The sample submitted for testing by adhesive for tiles Ceramic adhesion mortar- grey is classified as a type CITE adhesive according to the EN 12004:2007+A1:2012

Laboratory manager : 
/ eng. H. Angelova /

